



# Department Report

---

Report Title: Water & Wastewater Treatment Department Report May 2025

Report Highlight: The annual Consumer Confidence Report for CY2024 was completed this month and made available to our customers. This year's report had to contain information on Service Line Inventory as well as how the public can obtain a copy for the entire system. All testing that was performed in the previous year met all of the safe levels for drinking water in accordance to the Safe Drinking Water Regulations of the State of Georgia. Willow Contractors have started the Lime Tank Project at the Wastewater Plant. It will take a couple of months to completely install the 16,000-gallon tank and building that will contain all the chemical pumps and control panels for this treatment process. Turnipseed Engineering is overseeing the construction of this project to ensure that it is built to the specifications that was approved by the Georgia EPD.

Name and Title: John Jarrard, Water/Wastewater Treatment Director

## Recently Completed

- Replaced O-rings on Screen A at WTP
- Consumer Confidence Report (CCR) for CY2024 submitted to EPD
- Replaced diaphragm on caustic pump
- Washed out Floc chamber and filters at WWTP
- Replaced Pump #2 at Ranger Camp Station
- Collected 129 Priority Pollutant Tests on WWTP Effluent
- Cleaned out both UV Chambers
- Pumped plastics and floatable from Old Water Plant and Highland Trace Stations
- Replaced control fuses at College Pump Station
- Sky Country Tank Washout and Inspection (ATM Maintenance Contract)

## Underway:

- Replacement of Pump #1 at Highland Trace Lift Station
- Repairs to CIP circulation pump at WTP
- Caustic Tank valve repair at WWTP
- Air Supply Line repair on Rack #3 at WTP
- Repairs to pump #1 at Pizza Hut Lift Station
- Whole Effluent Toxicity (WET) testing on WWTP Effluent

## Near Term:

- Retaining Wall at Wimpy Will Lift Station
- Koyo Lift Station Rehab Project