



Department Report

Report Title: Water & Wastewater Treatment Department Report December 2025

Report Highlight: The on-site part of the Sanitary Survey has been completed for the water system. The inspector meticulously went thru the files of the water treatment plant, distribution system as well as the Cross-Connection/Backflow Program and their facilities. We should receive the final report by the end of January. At the time will have 45 days to respond to any findings noted in the report and our plan of action to correct them. Data gathering for the annual water audit has begun. This is one of the most important EPD requirements that has to be completed by March 1st of each year. Once the report is finalized, a State Certified Water Auditor must complete a review of the report.

Name and Title: John Jarrard, Water/Wastewater Treatment Director

Recently Completed

- Annual Preventive Maintenance on large lift stations
- Industrial Pre-Treatment site inspections (Koyo and Tysons)
- Sanitary Survey site inspections
- Installed soft-start on CIP Recirculation Pump
- Calibrated DO probes in SBR basins
- Pumped out Wal-Mart, Highland, Owens Farm Lift Stations
- Replaced temperature sensor on Sodium Hypochlorite Generator
- Replaced guiderails in High School Lift Station
- Wash of filter EQ basin at WWTP
-

Underway:

- Repairs to Wal-Mart Altitude Valve
- Replace seals on floc mixer at WTP
- Repairs to Singer Valve #4
- Repairs to Pump #2 at Ranger Camp Lift Station
- Air Supply Line repair on Rack #3 at WTP
- Repairs to pump #1 at Pizza Hut Lift Station
- PAC Feeder Repairs
- Replacement of In-line Turbidity Meters at WTP

Near Term:

- Annual Water Audit
- Retaining Wall at Wimpy Will Lift Station
- Koyo Lift Station Rehab Project
- Portable generator pricing