



# Department Report

Report Title: Water & Wastewater Treatment Department Report November 2025

Report Highlight: Georgia Power has restored the electricity to the Wal-Mart Lift Station as well as the Raw Water Intake. Due to the new footbridge being installed at the reservoir, power poles had to be relocated. Both facilities have been operating off of diesel fueled pumps and motors since the start of the project. With normal operations in place, preventive maintenance service has been performed on the standby generator to insure its reliability for the next emergency event. The rental pump for the lift station is being returned to the supplier. The two borrowed generators from GRWA are being stored in the old transfer station across from the WWTP. This site has been offered to them for a dry storage area until another community system needs them.

Name and Title: John Jarrard, Water/Wastewater Treatment Director

## Recently Completed

- Installed rebuilt pump at Porter Village Lift Station
- Repaired gearbox and motor to digester pump
- Installed new weather station at wastewater facility
- Replaced belts on blowers to sodium hypochlorite system
- Trimmed trees around all storage tanks
- Repairs to SBR Blower #1 at WWTP
- Collected and delivered THM/HAA Samples to the state lab
- Replaced guide rails in Wagon Wheel Lift Station
- Installed new electrical contactors in recycle station at WWTP
- Ventilation fan motor replaced in compressor room
- Power restored to Wal-Mart LS and Raw Water Intake

## Underway:

- EPD Sanitary Survey
- EQ Tank cleanout at WWTP
- Repairs to Pump #2 at Ranger Camp Lift Station
- Air Supply Line repair on Rack #3 at WTP
- Repairs to pump #1 at Pizza Hut Lift Station
- PAC Feeder Repairs

## Near Term:

- Retaining Wall at Wimpy Will Lift Station
- Koyo Lift Station Rehab Project
- Portable generator pricing
- Replacement of In-line Turbidity Meters at WTP