



# Department Report

---

Report Title: Water & Wastewater Treatment Department Report March 2026

Report Highlight: The 2025 Consumer Confidence Report (CCR) has been completed and submitted to the state. This annual report is required by the EPD to inform our customers of any violations that may have occurred during the previous calendar year with their drinking water as well as some of the test results. It also includes information on when our Council Meetings are conducted and information on new drinking water regulations and water restrictions that may be in effect for our system. We are required by law to post this report in a public location (City Hall) and provide an electronic copy and hard copy if so desired. Notices of the CCR are usually placed on water bills informing the customer of this report and on our website.

Name and Title: John Jarrard, Water/Wastewater Treatment Director

## Recently Completed

- Repaired Singer Valve #3 and #4
- Repairs to Koyo Lift Station Generator
- Replaced solenoid valve on barscreen
- Replaced two float switches in College Lift Station
- Installed emergency call system in Legion Lift Station
- Washed both basins and filter tanks at WWTP
- Serviced all three blowers at WWTP
- Ordered Portable Generator
- Annual Consumer Confidence Report (CCR)
- Replaced ejector on PAC Feeder
- Relabeled Exterior Storage Tanks at WTP
- Painted Crown Mountain Pump Station

## Underway:

- Lower Crown Mountain Tank Washout and Inspection
- Air Supply Line repair on Rack #3 at WTP
- Repairs to pump #1 at Pizza Hut Lift Station
- Quotes on repairs to Raw Water Pump #1 and Finished Water Pump #2
- Replacement of Chlorine Pump #4 at WTP
- FY2027 Budget (Capital and General Ledger Items)

## Near Term:

- Retaining Wall at Wimpy Will Lift Station
- Koyo Lift Station Rehab Project
- Valve replacement on finished water lines at WTP